| | ENGINEE | ERING STA | NDARDS | |
|--|---|-----------|---|---|
| Rosedale Products, Inc. 1730 West Liberty Road Ann Arbor, MI 48103 | IOM 7_4_5 Model 8 150.wpd n:\iom\ | | <i>Issue Date: 07NOV95 Revision: E Revision Date: 30May2003</i> | Specification No. 7.4.5 PAGE: 1 of 0 |
| IN | STALLATION, OPERA | TION, & I | AINTENANCE MANUAL | |
| INST | TALLATION MAINTEN | | ERATION AN EMANUAL | ND |
| | ROSEDA | LE PRODUC | CTS, INC. | |
| | [| | ® | |

MODEL 8

150 PSIG RATED FILTER UNIT

Table of Contents

| I. | Installation | 2 |
|------|---------------------|---|
| II. | Operation | 3 |
| III. | Spare Parts List | 4 |
| IV. | Spare Parts Diagram | 5 |

Rosedale Engineering Standards are the property of Rosedale Products, Inc. A Rosedale standard or copy thereof shall not be distributed (except with express approval of Rosedale Products, Inc.) to any individual or firm beyond the intended recipient firm or individual. Firms of individuals acting contrary to the above may be subject to suit, ineligibility for continued or future employment, or removal from Rosedale's "Approved Manufacturers and Specialty Contractors List".

ENGINEERING STANDARDS

Rosedale Products, Inc. 3730 West Liberty Road Ann Arbor, MI 48103

7_4_5 Model 8 150.wpd n:\iom\

IOM

Issue Date: 07NOV95 Revision: E Revision Date: 30May2003

INSTALLATION, OPERATION, & MAINTENANCE MANUAL

I. Installation

Please remove all shipping and crating materials carefully. Be sure to remove the plugs from the inlet and outlet openings. Dispose of all crating materials safely.

The Model 8 Filter unit is capable of having several different piping variations based upon the outlet style of your unit. The inlet service line should be connected to the inlet flange or NPT coupling located near the top of the unit (above the basket level).

The outlet service line should be connected to the outlet flange or coupling, located near the middle or bottom of the unit depending upon the style of your unit (below basket level).

There are two 1/4" NPT ports on the shell and one 1/4" NPT port on the cover of the Model 8 Filter unit. These ports can remain plugged or used for pressure gauges or special fittings as your application requires.

Some installations require electrical grounding of all equipment, be sure to provide adequate grounding where necessary.

After completing installation be sure to double check connections for integrity. Your Model 8 Filter unit has been factory pressure tested leak free, therefore, any seepage problems usually occur from improper installation connections.

You are now ready to install the filter basket and bag. Remove cover by loosening the cover eyenuts. The eyenuts in the slotted corners should be loosened sufficiently to swing free. Loosen the third eyenut sufficiently to allow the top cover and closure assembly to swing away from the top of the unit.

If your application requires a basket seal, insert the basket seal into the basket collar groove. Refer to Figure 1 or Figure 2 in the Spare Parts Diagram for installation position of your seal.

Place the basket into the filter housing, make sure the basket flange is firmly seated into the basket collar.

Insert bag into the bag basket making sure filter bag ring is firmly seated inside the basket flange. For best results, be sure filter bag is installed fully extended to the bottom of the basket.

Before replacing cover assembly, inspect cover seal gasket (replacing as necessary). Close cover and alternately tighten the three clamp assemblies evenly to ensure a leak proof seal between the cover and housing body. Torque closure assemblies to a maximum of 60-90^{ft-lbs}. Each installation may have different closure bolting torque requirements to effectively seal the filter vessel cover. Many installations require significantly lower closure bolting torque due to the variables explained below. The suggested torque values are for reference only. They are to be used as a guideline by maintenance personnel. These values are meant as a guideline for safe operation of the filter system at its maximum rated pressure. Many variables affect the torque required to operate the filter vessel without leaks. These variables include the diameter of the bolt, type and number of threads, material type and grade, condition of the nut bearing surface and lubrication of bolt threads and nut bearing surfaces. Other factors such as the condition of the o-ring, o-ring material, viscosity of the fluid being filtered, operating pressures, temperature, and the closure assembly tightening procedure must also be considered.

Your Rosedale Model 8 is now ready for operation!

Rosedale Engineering Standards are the property of Rosedale Products, Inc. A Rosedale standard or copy thereof shall not be distributed (except with express approval of Rosedale Products, Inc.) to any individual or firm beyond the intended recipient firm or individual. Firms of individuals acting contrary to the above may be subject to suit, ineligibility for continued or future employment, or removal from Rosedale's "Approved Manufacturers and Specialty Contractors List".

ENGINEERING STANDARDS

Rosedale Products, Inc. 3730 West Liberty Road Ann Arbor, MI 48103

7 4 5 Model 8 150.wpd n:\iom\

IOM

Revision: E

Issue Date: 07NOV95 Revision Date: 30May2003

INSTALLATION, OPERATION, & MAINTENANCE MANUAL

II. Operation

Filter System Start-Up Procedure:

Prior to turning on the flow to the inlet service, please make the following checks:


- 1. Check inside filter unit to be sure basket and filter bag (if applicable) are in housing and do not require cleaning or replacement. If necessary install a clean filter basket and bag (if applicable).
- 2. Check that filter unit cover is securely fastened to housing. You are now ready to open the flow to the inlet service line. Slowly open the inlet service line approximately 25% of normal operational flow (open slowly as not to displace filter bag inside the housing). After filter unit is pressurized and vented, slowly open outlet service line unit valve until completely open. Complete opening of inlet service line until desired flow rate is reached.

Once the desired service flow has been established, the filter will operate efficiently until dirty. However, under no circumstances should more than 15 PSI Differential Pressure through the filter be obtained. Operating the filter unit with a high differential may cause filter bags to rupture and/or cause damage to filter system and downstream equipment.

To prevent excessive drop through the filter unit, regular inspection of the filter media is required. Monitoring of differential pressure through the housing can be utilized as a means of determining whether or not the filter media needs cleaning or replacement.

When it becomes necessary to clean or replace filter media, follow the procedure outlined below:

- 1. First close the flow from the inlet service line.
- 2. Close the flow to the outlet service line. (In some applications closing flow to outlet is not required.)
- 3. Relieve the pressure from the filter unit.



- 4. Drain housing sufficiently to access filter basket.
- 5. Remove cover by loosening the cover evenuts. The evenuts in the slotted corners should be loosened sufficiently to swing free. Loosen the third evenut sufficiently to allow the top cover and closure assembly to swing away from the top of the unit.
- 6. Remove filter basket and clean thoroughly, remove the filter bag (if applicable) and throw away. (Cleaning and reusing the filter bag is not recommended.)
- 7. Remove debris and sludge from inside the inlet portion of housing to avoid interference with cover seal or flow of fluid being filtered.
- 8. Remove basket seal and inspect, replace if necessary. Clean basket seal groove and replace

Rosedale Engineering Standards are the property of Rosedale Products, Inc. A Rosedale standard or copy thereof shall not be distributed (except with express approval of Rosedale Products, Inc.) to any individual or firm beyond the intended recipient firm or individual. Firms of individuals acting contrary to the above may be subject to suit, ineligibility for continued or future employment, or removal from Rosedale's "Approved Manufacturers and Specialty Contractors List".

| | ENGINEE | ERING STA | ANDARDS | |
|--|---|--|---|---|
| Rosedale Products, Inc. 3730 West Liberty Road Ann Arbor, MI 48103 | IOM 7_4_5 Model 8 150.wpd n:\iom\ | | Issue Date: 07NOV95 Revision: E Revision Date: 30May2003 | Specification No. 7.4.5 PAGE: 4 of 6 |
| IN | STALLATION, OPERA | ATION, & I | AINTENANCE MANUAL | |
| 9. I r i b 10. I 11. M e r | make sure the basket flange is f into the bag basket making sure best results, be sure filter bag is Inspect cover gasket for cuts or Move cover back into position, ensure a leak proof seal betwee | ilter bag (if ap firmly seated i e filter bag ring s installed full r other signs of , and alternatel en cover and h installations re | plicable). Place the basket into the filter nto the basket collar. If applicable, inse g is firmly seated inside the basket flang y extended to the bottom of the basket. f failure and make sure it is properly sea ly tighten the three clamp assemblies even ousing body. Torque closure assemblies quire significantly lower closure bolting | ert bag ge. For nted. enly to s to a |
| | odel 8 Filter unit is now ready f | for operation. | Refer to filter system start-up procedure | e. |
| III. Spare Pa | irts List | | | |

Your Rosedale Model 8 Filter unit will give you many years of reliable service provided periodic inspections are made of various components and replacement of worn parts are made promptly. The following is meant to be a recommended spare parts list, these parts are illustrated on the following page.


| | SPARE PAR | TS LIST | |
|---------|---------------------|-------------|------------|
| Balloon | Description | Part Number | Time-Frame |
| 1 | Cover Seal | 8150CG-* | as needed |
| 2 | Basket Seal | 8BG-* | as needed |
| 3 | Cover | 8*150 | as needed |
| 4 | Eye Nut | 8ENNI | as needed |
| 5 | Rod End | 8RENI | as needed |
| 6 | Clevis Pin Assembly | 8CPNI | as needed |
| 7 | Filter Bag | (See Order) | as needed |
| 8 | Filter Basket | (See Order) | as needed |
| 9 | Tripod Legs | 8T22*S | as needed |

* Select Material Designation:

C=Carbon Steel S=304 Stainless Steel S316=316 Stainless Steel

B=Buna N E=Ethylene Propylene V=Viton TEV=Teflon Encapsulated Viton TSW=Teflon Solid White

Rosedale Engineering Standards are the property of Rosedale Products, Inc. A Rosedale standard or copy thereof shall not be distributed (except with express approval of Rosedale Products, Inc.) to any individual or firm beyond the intended recipient firm or individual. Firms of individuals acting contrary to the above may be subject to suit, ineligibility for continued or future employment, or removal from Rosedale's "Approved Manufacturers and Specialty Contractors List".



| ENGINEERING STANDARDS |
|-----------------------|
|-----------------------|

Rosedale Products, Inc. 3730 West Liberty Road Ann Arbor, MI 48103

ЮМ 7 4 5 Model 8 150.wpd n:\iom\

Revision: E

Issue Date: 07NOV95 Revision Date: 30May2003

Specification No. 7.4.5 PAGE: 6 of 6

INSTALLATION, OPERATION, & MAINTENANCE MANUAL

Important Notice

Warranty: In the event any Rosedale Products, Inc. filtration product is found to be defective in material, workmanship, or not in conformance with any express warranty for a specific purpose, Rosedale's only obligation and your exclusive remedy, shall be to repair, replace or refund the purchase price of such parts or products upon timely notification thereof and substantiation that the product has been stored, maintained and used in accordance with Rosedale's written instructions.

EXCLUSIONS TO WARRANTY: THIS WARRANTY IS EXCLUSIVE AND IS IN LIEU OF ANY IMPLIED WARRANTY OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHER WARRANTY OF QUALITY, EXCEPT OF TITLE AND AGAINST PATENT INFRINGEMENT.

LIMITATION OF LIABILITY: Except as provided above. Rosedale shall not be liable or responsible for any loss or damage. whether direct, indirect, incidental, special or consequential, arising out of sale, use or misuse of Rosedale filtration products, or the user's inability to use such products.

THE REMEDIES SET FORTH HEREIN ARE EXCLUSIVE.

Rosedale Products, Inc. 3730 West Liberty Road Ann Arbor, MI 48103 USA 734-665-8201 800-821-5373 Fax. 734-665-2214 filters@rosedaleproducts.com http://www.rosedaleproducts.com

Rosedale Engineering Standards are the property of Rosedale Products, Inc. A Rosedale standard or copy thereof shall not be distributed (except with express approval of Rosedale Products, Inc.) to any individual or time beyond the intended recipient firm or individual. Firms of individuals acting contrary to the above may be subject to suit, ineligibility for continued or future employment, or removal from Rosedale's "Approved Manufacturers and Specialty Contractors List".